

Addendum 1 - Comprehensive HVAC Master Maintenance Agreement
Invitation to Bid# 20180621-1-CO

Per Addendum 1 the following items of Invitation to Bid 20180621-1-CO XXII Specific Proposal Requirement Details have changed:

Under items to be included: Item d language is changed to:

Pricing shall include inspection of the main air handler(s) ductwork > s de>shaercie din ae>ssn aPr15((t))-2E
Inspect the main air handler(s) ductwork for leaks and repair (if necessary).

HVAC Contractor will be responsible for assisting Sumner County with answering questions regarding ductwork inspection reports if interested bidders/ductwork ask questions.

Clarification:

For analysis of chilled and hot water systems. Tests results shall be provided to Sumner County. Any chemical treatment required shall be completed by a professional certified water treatment firm. HVAC Contractor shall include the cost in bid price and provide firm qualifications with bid submittal.

Interested bidders for the HVAC Maintenance Agreement will be required to acknowledge Addendum 1 in order for their bid to be valid. This form must be included with bid submittal.

Acknowledgement of Addendum 1:

HVAC Contractor Acknowledgement of Addendum by Signature

Date